

FORM 0124
Rev. 4/83

WELL COMPLETION REPORT

WELL PERMIT NO. SE0307E
 COLLIER ENTERPRISES PODANAWER AB TOMOKALEE FLORIDA 33934
 City 100 State 175 Total Depth A-7
 Address 1-21-87 Completion Date
 Contractor Name GARY BRIFFEY License No. E40045
 Driller's Name 1 1/2 months

TYPE OF WORK: Construct Repair Abandon
 WELL USE: Domestic Well Public Monitor Test Jet
 Irrigation Fire Well Other
 METHOD: Rotary with MUD or Air Cable Tool Jet
 Casing Driven Other
 STATIC WATER LEVEL 5 Ft. below top of casing
 PUMPING WATER LEVEL 5 Ft. after 5 Hrs. at 5 GPM
 PUMP SIZE 1/2 H.P. CAPACITY 5 GPM
 PUMP TYPE INTAKE DEPTH From top of ground

	X		

LOCATION
 Located Near ESIDE RT 29
NOV NEW MARKET RD
 County COLLIER
SE NW 28 46S 28E
 Section Township Range
 Latitude-Longitude

Cuttings sent to District? Yes
 No
 Note: PWS Wells attach a site map if well location is different from site location on permit application.

Casing & Screen Diameter & Depth	Depth (ft)		DRILL CUTTINGS LOG Examine cuttings every 20 ft Give color, grain size, and type of material. depth to produce zones
	From	To	
3 1/2 18 1/2	0	10	SAND
4 1/2 18 1/2	10	15	VERY CLAY
4 1/2 18 1/2	15	40	SOIL FERTILIZER SAND
4 1/2 18 1/2	40	50	SAND NO FERTILIZER
4 1/2 18 1/2	50	61	CLAY
4 1/2 18 1/2	61	75	SOIL FERTILIZER SAND
4 1/2 18 1/2	75	82	CLAY
4 1/2 18 1/2	82	79	SOIL FERTILIZER SAND
4 1/2 18 1/2	79	75	SAND NO FERTILIZER
4 1/2 18 1/2	75	100	WHITE LOSS OF DRILLING FLUID

Casing: Black Steel Galv. PVC Fiberglass
 Screen: Type PVC Slot size 0.045
 Screened from 10 (ft.) to 100 (ft.)
 Type of grout with % additives NEAT CEMENT
 Water: Clear Colored Sulphur Salty Iron
 Chlorides 1000 mg/l
 Conductivity 39