

Station: IMWI-NO2

Form FD 9000-24  
GROUNDWATER SAMPLING LOG

SITE NAME: <b>IMWMD FOOD BANK #2</b>		SITE LOCATION: <b>1stok paper Brighton-Seminole Indian Reservation, Okeechobee, Florida</b>	
WELL NO: <b>#2</b>		SAMPLE ID: <b>#2</b>	
		DATE: <b>8/15/14</b>	

PURGING DATA

WELL DIAMETER (inches):	TUBING DIAMETER (inches):	WELL SCREEN INTERVAL DEPTH: feet to feet	STATIC DEPTH TO WATER (feet):	PURGE PUMP TYPE OR BAILER: Peristaltic
<b>WELL VOLUME PURGE: 1 WELL VOLUME = (TOTAL WELL DEPTH - STATIC DEPTH TO WATER) X WELL CAPACITY</b> (only fill out if applicable) = (                      feet -                      feet) X                      gallons/foot =                      gallons				
<b>EQUIPMENT VOLUME PURGE: 1 EQUIPMENT VOL. = PUMP VOLUME + (TUBING CAPACITY X TUBING LENGTH) + FLOW CELL VOLUME</b> (only fill out if applicable) =                      gallons + (                      gallons/foot X                      feet) +                      gallons =                      gallons				

INITIAL PUMP OR TUBING DEPTH IN WELL (feet):		FINAL PUMP OR TUBING DEPTH IN WELL (feet):		PURGING INITIATED AT:		PURGING ENDED AT:		TOTAL VOLUME PURGED (gallons):			
TIME	VOLUME PURGED (gallons)	CUMUL. VOLUME PURGED (gallons)	PURGE RATE (gpm)	DEPTH TO WATER (feet)	pH (standard units)	TEMP. (°C)	COND. (circle units) $\mu\text{mhos/cm}$ or $\mu\text{S/cm}$	DISSOLVED OXYGEN (circle units) $\text{mg/L}$ or % saturation	TURBIDITY (NTUs)	COLOR (describe)	ODOR (describe)
9:06					8.46	26.1	345.9	0.16	0.58	colorless	sulfur
9:09					8.52	26.1	346.0	0.11	0.31		
9:12					8.55	26.1	345.9	0.09	0.04		

WELL CAPACITY (Gallons Per Foot): 0.75" = 0.02; 1" = 0.04; 1.25" = 0.06; 2" = 0.16; 3" = 0.37; 4" = 0.65; 5" = 1.02; 6" = 1.47; 12" = 5.88  
 TUBING INSIDE DIA. CAPACITY (Gal./Ft.): 1/8" = 0.0006; 3/16" = 0.0014; 1/4" = 0.0026; 5/16" = 0.004; 3/8" = 0.006; 1/2" = 0.010; 5/8" = 0.016  
 PURGING EQUIPMENT CODES: B = Bailer; BP = Bladder Pump; ESP = Electric Submersible Pump; PP = Peristaltic Pump; O = Other (Specify)

SAMPLING DATA

SAMPLED BY (PRINT) / AFFILIATION:				SAMPLER(S) SIGNATURE(S):				SAMPLING INITIATED AT:		SAMPLING ENDED AT:	
PUMP OR TUBING DEPTH IN WELL (feet):				TUBING MATERIAL CODE:		FIELD-FILTERED: Y N Filtration Equipment Type:		FILTER SIZE: _____ $\mu\text{m}$			
FIELD DECONTAMINATION: PUMP Y N				TUBING Y N (replaced)				DUPLICATE: Y N			
SAMPLE CONTAINER SPECIFICATION				SAMPLE PRESERVATION			INTENDED ANALYSIS AND/OR METHOD	SAMPLING EQUIPMENT CODE	SAMPLE PUMP FLOW RATE (mL per minute)		
SAMPLE ID CODE	# CONTAINERS	MATERIAL CODE	VOLUME	PRESERVATIVE USED	TOTAL VOL ADDED IN FIELD (mL)	FINAL pH					
	1	PE	250 mL	HN03			Arsenic (6020)	APP			
REMARKS:											
MATERIAL CODES: AG = Amber Glass; CG = Clear Glass; PE = Polyethylene; PP = Polypropylene; S = Silicone; T = Teflon; O = Other (Specify)											
SAMPLING EQUIPMENT CODES: APP = After Peristaltic Pump; B = Bailer; BP = Bladder Pump; ESP = Electric Submersible Pump; RFPP = Reverse Flow Peristaltic Pump; SM = Straw Method (Tubing Gravity Drain); O = Other (Specify)											

NOTES: 1. The above do not constitute all of the information required by Chapter 62-160, F.A.C.  
 2. STABILIZATION CRITERIA FOR RANGE OF VARIATION OF LAST THREE CONSECUTIVE READINGS (SEE FS 2212, SECTION 3)  
 pH:  $\pm 0.2$  units Temperature:  $\pm 0.2$  °C Specific Conductance:  $\pm 5\%$  Dissolved Oxygen: all readings  $\leq 20\%$  saturation (see Table FS 2200-2); optionally,  $\pm 0.2$  mg/L or  $\pm 10\%$  (whichever is greater) Turbidity: all readings  $\leq 20$  NTU; optionally  $\pm 5$  NTU or  $\pm 10\%$  (whichever is greater)