



### WELL TEST ANALYSIS

Data Set: Z:\...\KRBNNNS.aqt  
 Date: 06/02/16

Time: 12:21:33

### PROJECT INFORMATION

Company: SFWMD  
 Client: SFWMD  
 Test Well: KRBNNNS  
 Test Date: 1/15/1997

### AQUIFER DATA

Saturated Thickness: 27.24 ft

Anisotropy Ratio (Kz/Kr): 0.25

### WELL DATA (KRBNNNS)

Initial Displacement: 4.8 ft  
 Total Well Penetration Depth: 19.97 ft  
 Casing Radius: 0.083 ft

Static Water Column Height: 19.97 ft  
 Screen Length: 4. ft  
 Well Radius: 0.25 ft  
 Gravel Pack Porosity: 0.

### SOLUTION

Aquifer Model: Unconfined  
 K = 2.962 ft/day

Solution Method: Bower-Rice  
 y0 = 0.8439 ft