



WELL TEST ANALYSIS

Data Set: Z:\...\KRCFFS.aqt  
 Date: 06/02/16

Time: 12:34:00

PROJECT INFORMATION

Company: SFWMD  
 Client: SFWMD  
 Test Well: KRCFFS  
 Test Date: 1/13/1997

AQUIFER DATA

Saturated Thickness: 33.16 ft

Anisotropy Ratio (Kz/Kr): 0.25

WELL DATA (KRCFFS)

Initial Displacement: 2.67 ft  
 Total Well Penetration Depth: 18.4 ft  
 Casing Radius: 0.083 ft

Static Water Column Height: 16.14 ft  
 Screen Length: 4. ft  
 Well Radius: 0.25 ft  
 Gravel Pack Porosity: 0.

SOLUTION

Aquifer Model: Unconfined  
 K = 20.82 ft/day

Solution Method: Bower-Rice  
 y0 = 1.164 ft