



WELL DRILLING REPORT

Well: 13

Location: E. Golden Gate W. Sec 17, T49S, R2E

County: Collier State: FL

Ground Elevation: 13 ft +

Diameter: 12 inches

Depth: 100 feet

Static Water Level: 1.9'

Date: 9-81

Casing: 14 inch to 40' com

Screen: open hole

Construction: Air Rotary

Driller: Tamiami Well I Ft. Myers, FL

Date Finished: 1981

Pumping Test

Specific Yield 318 g
@ 1150 gpm

Water Analysis (ppm)	
TDS	<u>403</u>
Total Hardness ¹	<u>808</u>
M.O. Alkalinity ¹	<u>334</u>
Chloride Cl	<u>39</u>
Iron Fe	<u>0.05</u>
Sulfate SO ₄	<u>8.8</u>
Color (APHA)	<u>25</u>
Calcium ¹	<u>225</u>

Compiled by Reynolds
Date 10-81

¹ As CaCO₃.