



WELL DRILLING REPORT

Well: 16 (1-N)

Location: E. Golden Gate Ln. F. Sec. 32, T48S, R28E

County: Collier State: FL

Ground Elevation: 13' ±

Diameter: 12

Depth: 137

Static Water Level: 2.25'

Date: 10-81

Casing: 14" to 39" fa cemented

Screen: open hole

Construction: Air Rotary

Driller: Tomiani Well Drilling FL. Myers FL

Date Finished: 10-81

Pumping Test

Specific Yield 738 gpm/ft @ 1100 gpm

Water Analysis (ppm)

TDS	<u>359</u>
Total Hardness ¹	<u>279</u>
M.O. Alkalinity ¹	<u>274</u>
Chloride Cl	<u>35</u>
Iron Fe	<u>0.70</u>
Sulfate SO ₄	<u>22</u>
Color (APHA)	<u>25</u>
Calcium ¹	<u>241</u>

Compiled by S.F. Reynolds
Date 11-81

¹ As CaCO₃.