



WELL DRILLING REPORT

Well: 17 (2-A)
 Location: E. Golden Gate W.F.
Sec 32, T48S, R28E
 County: Collier State: FL
 Ground Elevation: 13' ±
 Diameter: 12"
 Depth: 117
 Static Water Level: 2.50
 Date: 10-81
 Casing: 14" steel to 40'
cemented
 Screen: open hole
 Construction: Air rotary
 Driller: Tamiami Well Drilling
Ft. MYERS, FL
 Date Finished: 10-81

Pumping Test

Specific Yield 442 gpm/ft
 @ 1100 gpm

Water Analysis (ppm)

TDS	<u>343</u>
Total Hardness ¹	<u>268</u>
M.O. Alkalinity ¹	<u>276</u>
Chloride Cl	<u>39</u>
Iron Fe	<u>0.05</u>
Sulfate SO ₄	<u>6.4</u>
Color (APHA)	<u>25</u>
Calcium ¹	<u>217</u>

Compiled by S. F. Reynolds
 Date 11-81

¹ As CaCO₃.