

06/14/2006 11:01

2395748106

Collier 11-02591
WRS

CO-1043

Black, Crow and Eidsness, Inc.
Engineers
Gainesville, Florida

WELL DRILLING REPORT

Depth Classification Log Well TDS

| | | |
|-----|---|-----|
| 10 | SAND & LIMESTONE (brown) | |
| | SAND & LIMESTONE (gray) | |
| 20 | LIMESTONE (gray, hard) | |
| | LIMESTONE & SHELL (coarse) | |
| 30 | LIMESTONE & SHELL (hard) | |
| | SAND & SHELL | |
| 40 | SAND, SHELL & LIMESTONE | |
| | LIMESTONE (coarse) | |
| 50 | LIMESTONE (fine) | |
| | LIMESTONE (coarse) | |
| 60 | LIMESTONE & SAND (med-hd) | 405 |
| | SAND & LIMESTONE | |
| 70 | SAND, LIMESTONE & BL. CLAY | |
| | SHELL, LIMESTONE & BLUE CLAY | 420 |
| 80 | SHELL, LIMESTONE & GR CLAY | 405 |
| | LIMESTONE (blue, hard) | |
| 90 | LIMESTONE (gray, very hard) | 420 |
| | LIMESTONE (blue, wt & hd) | 405 |
| 100 | LIMESTONE (white, coarse & medium hard) | 414 |
| | LIMESTONE & CLAY (brn-slt) | |
| 110 | LIMESTONE (wht, med-hd) | |
| | SAND (cemented) | 405 |
| 120 | | |
| 130 | | |
| 140 | | |
| 150 | | |
| 160 | | |

477491
682539
~~477491~~
E. E. E.

Well: Test Well NA-7
City of Naples

Location: NE 1/4; Sec. 8; T49S; R28E

County: Collier State Fla.

Ground Elevation: +14 feet m. s. l.

Diameter: 6-inch

Depth: 155 ft.

Static Water Level: 4'-0" Below Ground

Date: 6-18-70

Casing: 75 ft.

Screen: None

Construction: Cable Tool

Driller: Meredith Corp. (George Mathis)

Date Finished: 6-18-70

Pumping Test
Specific Capacity 108 gpm/ft @ 800 gpm

| <u>Water Analysis (ppm)</u> | | | |
|-----------------------------|-----|--------------|---------|
| T. D. S. | 420 | Chloride Cl | 30 |
| Total Hard (l) | 276 | Iron | Fe 0.04 |
| M. O. Alkal. (l) | 276 | Sulfate SO4 | 3.0 |
| Calcium (l) | 237 | Color (APHA) | 31 |

Remarks

Compiled by RDGP Date 6-18-70

(l) as CaCO3