

Glean

W-12884

~~2434~~

ENGINEERING REPORT

RESULTS OF DRILLING AND TESTING
FLORIDAN AQUIFER WATER SUPPLY WELLS

FOR THE

CITY OF CAPE CORAL, FLORIDA

Project No. 212-7504-5

April, 1976

BLACK, CROW AND EIDSNES, INC.
Engineers
Gainesville, Florida

This Report has been prepared by Black, Crow and Eidsness, Inc., Consulting Engineers, as a professional service to our client. Reproductions or other publications of abstracts herein are prohibited without approval and consent of the Engineers.




FIGURE 1. Location map.

TABLE 1-1

DESCRIPTION OF AQUIFERS

Aquifer	Approximate Depth	Description	Water Bearing Properties
Water Table	0-30 feet	Sand and shell with some limestone layers.	Furnishes water for private irrigation wells. Yields generally low. Aquifer is susceptible to saltwater intrusion near salty surface water bodies.
Upper Hawthorn	150 to 250 feet	Sandy and shelly phosphatic limestone in the upper 100 feet or so of the Hawthorn formation. Overlain by sandy clay and marl beds which separate it from the water table aquifer.	Source of present supply. The water is under artesian conditions, but pumping has lowered artesian pressure well below land surface, and in some places below sea level. Water in the aquifer is generally potable except where faulty well construction has allowed salt water to enter.
Lower Hawthorn	350 to 650 feet	Sandy limestone in the lower part of the Hawthorn Formation and upper part of the Tampa Limestone.	Formerly source of supply, along with deeper aquifers, for many irrigation wells in the area. The water is under artesian pressure sufficient to produce free flowing wells in the area. Water in the aquifer is not potable, due to high salt and total solids content. Water quality appears to have improved following plugging of many old wells in the area.
Suwannee Aquifer	750 to 900+ feet	Limestone and dolomite in the upper part of the Suwannee Limestone. Separated from the overlying lower Hawthorn aquifer by 100 feet or so of dense limestone. May extend as deep as 1,100 feet.	Formerly the source of supply for many irrigation wells in the area. The water is under artesian pressure sufficient to produce free-flowing wells in the area. Water in the aquifer is not potable, and is normally more mineralized than water in the overlying lower Hawthorn aquifer.

212-75-04




FIGURE 2. Cape Coral test well chlorides vs. depth.




FIGURE 3. Geologic cross section.

TABLE 4-1

WELL INVENTORY DATA

Well No.	Location				Depth of Well, ft	Depth of Casing, ft	Chloride mg/l	Date of Data
	¼	¼	Sec.	Twp. Rge.				
1	SE	SE	31	43S 23E	818	131	1,200	2/69
2	SE	SE	31	43S 23E	553	132	--	12/69
3	NE	SE	32	43S 23E	--	--	1,260	2/69
4	NE	NW	36	43S 23E	731	132	--	8/69
5	SE	SW	36	43S 23E	--	--	1,940	2/69
6	SE	SW	31	43S 23E	977	--	--	12/69
7	SW	SW	31	43S 24E	425	--	740	2/69
8	NW	NE	32	43S 24E	1,155	--	480	10/56
9	SE	NE	32	43S 24E	700	--	--	9/57
10	NE	SE	32	43S 24E	830	--	580	10/56
11	SE	SE	1	44S 23E	619	133	1,000	2/69
12	NE	SE	1	44S 23E	1,001	157	--	8/69
13	SE	SE	2	44S 23E	706	143	655	6/58
14	SE	SE	3	44S 23E	511	155	--	8/69
15	NE	NE	3	44S 23E	1,045	159	880	2/69
16	SW	NE	3	44S 23E	919	137	980	2/69
17	SE	NE	3	44S 23E	642	157	640	2/69
18	SE	NE	3	44S 23E	510	155	900	2/69
19	NE	NW	6	44S 23E	--	--	900	2/69
20	SW	NE	6	44S 23E	--	--	900	2/69
21	NE	SE	6	44S 23E	--	--	840	2/69
22	NW	NE	6	44S 23E	832	122	--	12/69
23	SE	NE	7	44S 23E	468	128	960	2/69
24	SW	SE	8	44S 23E	601	156	940	2/69
25	NE	SE	9	44S 23E	--	--	--	--
26	NE	SE	10	44S 23E	800	--	--	10/56
27	NW	NE	11	44S 23E	--	--	820	9/57
28	NW	NE	11	44S 23E	515	164	670	6/58
29	SE	NE	11	44S 23E	835	162	2,380	3/69
30	NE	NE	11	44S 23E	857	170	--	8/66
31	NE	SW	12	44S 23E	--	--	670	6/58
32	NE	SW	12	44S 23E	512	117	740	2/69
33	NE	NW	13	44S 23E	585	151	--	1/65
34	NE	NW	13	44S 23E	--	--	720	10/56
35	NW	SE	13	44S 23E	300	--	240	10/56
36	NW	NE	13	44S 23E	700	156	--	1/65
37	SE	NE	13	44S 23E	815	132	--	1/65
38	SW	SW	14	44S 23E	--	--	--	9/57
39	NW	NW	15	44S 23E	--	--	540	3/69
40	SE	NW	15	44S 23E	225	--	84	10/56
41	SW	NE	15	44S 23E	--	--	660	2/69
42	SE	SW	15	44S 23E	--	--	--	9/57
43	SW	SE	15	44S 23E	683	159	--	1/65
44	SW	SE	15	44S 23E	800	--	600	10/56

TABLE 4-1 - (continued)

Well No.	Location			Depth of Well, ft	Depth of Casing, ft	Chloride mg/l	Date of Data
	¼	¼	Sec. Twp. Rge.				
45	SE	SE	15 44S 23E	790	--	640	10/56
46	NE	SE	15 44S 23E	796	163	--	10/56
47	SW	NW	17 44S 23E	468	126	1,200	2/69
48	SW	NW	17 44S 23E	--	--	620	2/69
49	SW	SW	17 44S 23E	390	117	--	10/64
50	SW	SE	17 44S 23E	978	--	--	10/71
51	NW	SE	18 44S 23E	--	--	--	9/57
52	NW	NW	19 44S 23E	--	--	780	10/56
53	SE	NE	19 44S 23E	1,000	--	640	10/56
54	NE	SW	19 44S 23E	--	--	640	10/56
55	NE	SE	20 44S 23E	--	--	360	10/56
56	NE	NE	21 44S 23E	700	--	480	10/56
57	NE	SW	21 44S 23E	700	--	600	10/56
58	SE	SW	21 44S 23E	--	--	220	10/56
59	NE	NW	22 44S 23E	660	70	800	10/56
60	SE	NE	22 44S 23E	--	--	520	10/56
61	NW	NE	23 44S 23E	808	133	--	1/65
62	NW	SE	24 44S 23E	590	177	--	5/60
63	NW	NE	25 44S 23E	1,000	--	880	10/56
64	SW	SW	25 44S 23E	1,000	--	560	10/56
65	NE	NW	27 44S 23E	157	42	--	9/57
66	NW	NW	27 44S 23E	444	112	--	3/65
67	SW	NW	27 44S 23E	630	--	560	10/56
68	NE	NW	28 44S 23E	--	--	240	10/56
69	SE	NW	28 44S 23E	--	--	620	10/56
70	SW	SE	32 44S 23E	--	--	600	10/56
71	SE	SE	32 44S 23E	--	--	600	10/56
72	NE	SW	33 44S 23E	--	--	560	10/56
73	SW	SW	33 44S 23E	--	--	600	10/56
74	SE	SE	36 44S 23E	1,000	--	1,000	10/56
75	NE	NW	6 44S 24E	660	--	660	2/69
76	SW	SE	6 44S 24E	--	--	1,040	2/69
77	SE	SW	8 44S 24E	728	206	--	2/65
78	SW	SE	8 44S 24E	1,071	156	--	2/65
79	NE	NE	17 44S 24E	436	194	--	2/65
80	NW	NE	18 44S 24E	610	--	--	5/60
81	SW	NW	20 44S 24E	676	136	--	1/65
82	NW	NW	30 44S 24E	946	150	--	1/60
83	NW	SE	30 44S 24E	1,081	157	--	1/60
84	SW	SE	31 44S 24E	1,140	--	--	1/60
85	SE	SE	31 44S 24E	1,110	137	--	1/60
86	SW	NW	2 45S 23E	730	46	--	1/65
87	NW	NW	2 45S 23E	403	--	--	5/60
88	NW	NE	2 45S 23E	628	--	--	5/60
89	NW	SW	2 45S 23E	636	143	--	1/65

TABLE 4-1 - (continued)

Well No.	Location			Depth of Well, ft	Depth of Casing, ft	Chloride mg/l	Date of Data
	¼	¼	Sec. Twp. Rge.				
90	NW	NW	2 45S 23E	728	--	--	5/60
91	SW	NW	2 45S 23E	818	48	--	1/65
92	NW	NW	3 45S 23E	545	105	--	5/60
93	C	NE	3 45S 23E	662	94	--	1/65
94	NE	NE	6 45S 24E	964	112	--	1/60
95	SE	SE	7 45S 24E	642	172	--	1/60

WELL DRILLING REPORT

Well CAPE CORAL R.O. WATER SUPPLY WELL No. 2

Location N. 1/2, N.W. 1/4, SECT. 4, T45S, R.23E

County LEE State FLORIDA

Elevation ≈ 6'

Diameter 11 in. Total Depth 745 ft.

Casing 12" SCHED. 40 PVC TO 362'

Screen NONE

Construction ROTARY

Driller McGREGOR PUMP Co. Inc.
FT. MYERS, FLA.

Date Finished 9-11-75

PERMANENT PUMP

Mfg. _____ Motor _____ HP
Capacity _____ gpm TDH _____ ft.
Strainer Setting _____ ft.

PUMPING TEST

Static water level 212 ft. Date 7 APR. 76


Specific capacity 50.4 gpm/ft @ 1070 gpm

WATER ANALYSIS (ppm)

TDS	<u>1180</u>	Chloride, Cl	<u>440</u>
Total Hard.*	<u>427.5</u>	Iron, Fe	<u>.03</u>
M.O. Alkal.*	<u>209</u>	Sulfate, SO ₄	<u>144</u>
Calcium*	<u>135</u>	Color (APHA)	<u>5</u>

Compiled by J.C.P. Date 10 APR. 76

* AS Ca CO₃



WELL DRILLING REPORT

Well CAPE CORAL R.O. WATER SUPPLY WELL No. 2

Location N. 1/2, N.W. 1/4, SECT. 4, T45S, R23E

County LEE State FLORIDA

Elevation 26'

Diameter 11 in. Total Depth 685 ft.

Casing 12" SCHED. 40 PVC TO 347

Screen NONE

Construction ROTARY

Driller McBREGOR PUMP CO INC

FT. MYERS

Date Finished 10-21-75

PERMANENT PUMP

Mfg. _____ Motor _____ HP

Capacity _____ gpm TDH _____ ft.

Strainer Setting _____ ft.

PUMPING TEST

Static water level 20.73 ft. Date 11-25-76

Specific capacity 102 gpm/ft @ 1500 gpm

WATER ANALYSIS (ppm)

TDS 1500 Chloride, Cl 502


Total Hard.* 482 Iron, Fe .06

M. O. Alkal.* 202 Sulfate, SO₄ 162

Calcium* 150 Color (APHA) 20

Compiled by J.C.P. Date 10 APR. 76

*As CaCO₃



WELL DRILLING REPORT

Well CAPE CORAL R.O. WATER SUPPLY WELL No. 3

Location N. 1/2, N.W. 1/4, SECT. 4, T45S, R23E

County LEE State FLORIDA

Elevation ≈ 6'

Diameter 11 in. Total Depth 705 ft.

Casing 12" SCHED. 40 PVC TO 345'

Screen NONE

Construction ROTARY

Driller Mc GREGOR PUMP CO. INC.

Date Finished 10-31-75

PERMANENT PUMP

Mfg. _____ Motor _____ HP

Capacity _____ gpm TDH _____ ft.

Strainer Setting _____ ft.

PUMPING TEST

Static water level 22.0 ft. Date 11-27-76

Specific capacity 34.4 gpm/ft @ 1350 gpm

WATER ANALYSIS (ppm)

TDS 1166 Chloride, Cl 350


Total Hard.* 421 Iron, Fe .02

M.O. Alkal.* 216 Sulfate, SO₄ 133

Calcium* 122 Color (APHA) 5

Compiled by J.C.P. Date 10 APR. 76

*As CaCO₃



Engineers
Gainesville, Florida

WELL DRILLING REPORT

Well CAPE CORAL R.O. WATER SUPPLY WELL No. 4

Location N. 1/2, N.W. 1/4, SECT. 4, T45S, R23E

County LEE State FLORIDA

Elevation ± 6'

Diameter 11 in. Total Depth 700 ft.

Casing 12" SCHED. 40 PVC TO 350'

Screen NONE

Construction ROTARY

Driller Mc GREGOR Pump Co. Inc.

Date Finished 12-13-75

PERMANENT PUMP

Mfg. _____ Motor _____ HP

Capacity _____ gpm TDH _____ ft.

Strainer Setting _____ ft.

PUMPING TEST

Static water level 21.3 ft. Date 7 APR. 76

Specific capacity 28.2 gpm/ft @ 508 gpm

WATER ANALYSIS (ppm)

TDS _____ Chloride, Cl _____


Total Hard.* _____ Iron, Fe _____

M. O. Alkal.* _____ Sulfate, SO₄ _____

Calcium* _____ Color (APHA) _____

Compiled by J.C.P. Date 10 APR. 76

*As CaCO₃



WELL DRILLING REPORT

Well CAPE CORAL R.O. WATER SUPPLY WELL No. 5

Location N. 1/2, N.W. 1/4, SECT. 4, T45S, R23E

County LEE State FLORIDA

Elevation ≈ 6'

Diameter 11 in. Total Depth 765

Casing 12" SCHED. 40 PVC TO 345'

Screen NONE

Construction ROTARY

Driller Mc GREGOR PUMP Co. INC.

Date Finished 1-21-76

PERMANENT PUMP

Mfg. _____ Motor _____

Capacity _____ gpm TDH _____

Strainer Setting _____

PUMPING TEST

Static water level 21.5 ft. Date 2-11-76

Specific capacity 17.2 gpm/ft @ 370 gp

WATER ANALYSIS (ppm)

TDS 904 Chloride, Cl 242


Total Hard.* 370 Iron, Fe .01

M.O. Alkal.* 224 Sulfate, SO₄ 102

Calcium* 100 Color (APHA) 5

Compiled by J.C.P Date 10 APR. 76

*As CaCO₃



WELL DRILLING REPORT

Well CAPE CORAL TEST WELL

Location N 1/2, NW 1/4, SECT. 4, T45S, R23E

County LEE State FLORIDA

Elevation ≈ 6'

Diameter 10 in. Total Depth 900 ft.

Casing 10" SCHED. 40 PVC TO 362'

Screen NONE

Construction ROTARY

Driller MR GREGOR PUMP Co. INC.

Date Finished MAY 1975

PERMANENT PUMP

Mfg. _____ Motor _____ HP

Capacity _____ gpm TDH _____ ft.

Strainer Setting _____ ft.

PUMPING TEST

Static water level 20.2 ft. Date 2-11-76

Specific capacity 86 gpm/ft @ 818 gpm

WATER ANALYSIS (ppm)

TDS 1340 Chloride, Cl 401

Total Hard.* 437 Iron, Fe .024

M.O. Alkal.* 198 Sulfate, SO₄ 170

Calcium* 135 Color (APHA) 5

Compiled by J.C.P Date 10 APR. 76

*As CaCO₃

