


Site Name **BF-6**
 Station Names BF-6
 Aquifers UFA
 FDEP Identifier Unknown
 Date of Summary 8/4/2017

Lat / Long: 261852/800726.16
 County: BROWARD
 Wellhead Repair Date: 2006, April 2014




Date of Photo: 2016

BF-6 Monitor Zone	
Casing Material:	PVC
Diameter:	12-inch
Data Range:	12/19/2016
Sampling Events Analyzed:	1
Water Type:	Na-Cl

Field Parameter Averages BF-6 Monitor Zone	
Field pH:	7.5
Specific Conductance (uS/cm)	5856
Temperature (Celcius)	27.9
TDS (mg/L)	3369
Water Level (ft NGVD 29)	43.5
Well Volume (gallons)	1657

BF-6 Monitor Zone Ionic Ranges	
Parameter	Concentration (mg/L)
Potassium (K)	32
Sodium (Na)	878
Calcium (Ca)	123
Magnesium (Mg)	126
Chloride (Cl)	1625
Bicarbonate (HCO3)	172
Sulfate (SO4)	354



Survey data: 2/17/2016 NGVD offset 1.57
 Reference elevation: 16.45 ft NAVD 88
 Access Agreement: Owned by City of Deerfield Beach; New Access Agreement Needed

References CDM, 1993. City of Deerfield Beach Floridan Aquifer Test/Production Well and Monitor Well Completion Report.
 SFWMD Survey date: 2/17/2016