



B3B-D, SLUG TEST 1

Data Set: K:\...\B3B-D_test1.aqt
 Date: 05/20/15

Time: 16:09:33

PROJECT INFORMATION

Location: LKB
 Test Date: 3/9/2005

AQUIFER DATA

Saturated Thickness: 170. ft

Anisotropy Ratio (K_z/K_r): 0.1

WELL DATA (B3B-D)

Initial Displacement: 8.611 ft
 Total Well Penetration Depth: 91. ft
 Casing Radius: 0.17 ft

Static Water Column Height: 91. ft
 Screen Length: 5. ft
 Well Radius: 0.42 ft
 Gravel Pack Porosity: 0.2

SOLUTION

Aquifer Model: Unconfined
 $K = 0.6281$ ft/day

Solution Method: Bouwer-Rice
 $y_0 = 9.269$ ft