

WELL COMPLETION REPORT


FORM 0124
Rev. 4/85

WELL PERMIT NO. _____

Owner USGS 6552 SE Federal Hwy Stuart FL 34997
 Address City State Zip
 License No. 2928 Completion Date 10/5/88 Casing Depth 35' Total Depth 45' Well # M-1250
 Contractor's Signature Tony Lubrano Registration No. _____
 Driller's Name

TYPE OF WORK: Construct () Repair () Abandon ()
 WELL USE: Domestic Well () Public () Monitor () Test ()
 Irrigation () Fire Well () Other _____
 METHOD: Rotary with MUD () or Air () , Cable Tool () , Jet ()
 Casing Driven () , Other _____
 STATIC WATER LEVEL _____ Ft. below top of casing
 PUMPING WATER LEVEL _____ Ft. after _____ Hrs. at _____ GPM
 PUMP SIZE _____ H.P. CAPACITY _____ GPM
 PUMP TYPE _____ INTAKE DEPTH _____
 From top of ground

LOCATION
 Located Near Fox Brown Rd
Allapattah Ranch Area
 County Martin
SWSE 34 38S 38E
 Section Township Range
270720 803120
 Latitude-Longitude



Cuttings sent to District? () Yes
 () No
Note: PWS Wells attach a site map if well location is different from site location on permit application.

Grout	Casing & Screen	Depth (ft)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Give color, grain size, and type of material. Note cavities, depth to producing zones.
		From	To	
2"	2"	0	15	Sand, dk brown
		15	25	orange sandstone
		25	46	coarse sand, silt
		46	56	shell, sand
		56	65	sand
	40' 2"	65	77	shell, sand
		77	96	shell, tan to black
		96	104	crystalline limestone
		104	120	(shells)
		120	139	shell green silt
		139	145	phosph. limestone, shell
Number of bags		145	151	shells, hard green clay (dry)
		151	158	soft dk green clay, shell

Casing: Black Steel () Galv. () PVC () Fiberglass ()
 Screen: Type PVC Slot size .02
 Screened from 35 (ft.) to 45 (ft.)
 Type of grout with % additives neat
 Water: Clear () Colored () Sulphur () Salty () Iron ()
 Conductivity _____ Chlorides _____ mg/l