

**WELL COMPLETION REPORT**

FORM 0124  
Rev. 4/85

**WELL PERMIT NO.** \_\_\_\_\_

Owner USGS Address 6552 SE Federal Hwy City Stuart State FL Zip 34997  
 License No. 2928 Completion Date 10/6/88 Casing Depth 85' Total Depth 85' Well # M1251  
 Contractor's Signature Tony Lubrano Registration No. \_\_\_\_\_  
 Driller's Name \_\_\_\_\_

TYPE OF WORK: Construct ( ) Repair (  ) Abandon ( )  
 WELL USE: Domestic Well ( ) Public ( ) Monitor (  ) Test ( )  
 Irrigation ( ) Fire Well ( ) Other \_\_\_\_\_  
 METHOD: Rotary with MUD (  ) or Air ( ), Cable Tool ( ), Jet ( )  
 Casing Driven ( ), Other \_\_\_\_\_  
 STATIC WATER LEVEL \_\_\_\_\_ Ft. below top of casing  
 PUMPING WATER LEVEL \_\_\_\_\_ Ft. after \_\_\_\_\_ Hrs. at \_\_\_\_\_ GPM  
 PUMP SIZE \_\_\_\_\_ H.P. CAPACITY \_\_\_\_\_ GPM  
 PUMP TYPE \_\_\_\_\_ INTAKE DEPTH \_\_\_\_\_  
 From top of ground

LOCATION  
 Located Near EC Matton  
Dairy, Beehive Hwy  
 County Martin  
NW NE 33 38 37  
 Section Township Range  
270750 803803  
 Latitude-Longitude


Cuttings sent to District? (  ) Yes  
 ( ) No

**Note: PWS Wells attach a site map if well location is different from site location on permit application.**

Grout	Casing & Screen	Depth (ft)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Give color, grain size, and type of material. Note cavities, depth to producing zones.
		From	To	
2"	2"	0	15	fine brown sand
		15	23	tan silt
		23	27	pink shell, green silt
		27	31	limestone, pink shell
		31	33	wood
70'		33	42	silt, shell fragm.
	75' 2"	42	60	shell, sand, silt
		60	65	dk gray clay
		65	85	shell, silt
		85	90	blue gray clay, shell
		85'	90	gray limestone, silt, shell
Number of bags		134	138	gray limestone, shell
9		138	142	green clay, shell

Casing: Black Steel ( ) Galv. ( ) PVC (  ) Fiberglass ( )  
 Screen: Type PVC Slot size 1020  
 Screened from 75' (ft.) to 85' (ft.)  
 Type of grout with % additives neat  
 Water: Clear ( ) Colored ( ) Sulphur ( ) Salty ( ) Iron ( )  
 Conductivity \_\_\_\_\_ Chlorides \_\_\_\_\_ mg/l