Company: Diversified Drilling Corp.
Well: SWROW TP-232
Field: Cape Coral
County: Lee
State/Prv: Florida

Company: Diversified Drilling Corporation
Well: SWROW TP-232
Field: Cape Coral
County: Lee
State/Prv: Florida
Location: SW corner of Chiquita & SW 17th Terrace
Cape Coral Water Utilities Department

FLUID CONDUCTIVITY TEMPERATURE LOG

All interpretations are opinions based on inferences from electrical or other measurements and we cannot and do not guarantee the accuracy or correctness of any interpretation, and we shall not, except in the case of gross or willful negligence on our part, be liable or responsible for any loss, costs, damages, or expenses incurred or sustained by anyone resulting from any interpretation made by any of our officers, agents or employees. These interpretations are also subject to our general terms and conditions set out in our current Price Schedule.

Comments

STATIC and DYNAMIC DOWN passes were performed.
Cw=9460 uS/cm @ 80.6 degF (Dynamic Sample). Q =~800 gpm.
FLUID RESISTIVITY CALIBRATION REPORT (Performed: 22-JAN-06 10:45))

uS/cm	CPS
408.4	3624.25
828.5	3660.58
1489.2	3234.36

TEMPERATURE CALIBRATION REPORT (Performed: 22-JAN-06 10:15)

DEG-F	CPS
34.8	2349.64
142.2	6966.21

STATIC FCT DOWN

Database File: ccro232.db
Dataset Pathname: run3/Dfct
Presentation Format: FCT232
Dataset Creation: Thu Mar 02 15:30:37 2006
Charted by: Depth in Feet scaled 1:240



STATIC FCT DOWN

Database File: ccro232.db
Dataset Pathname: run3/sfct
Presentation Format: FCT232
Dataset Creation: Thu Mar 02 15:23:14 2006
Charted by: Depth in Feet scaled 1:240