

WELL COMPLETION REPORT

FORM 0124
Rev. 4/85

WELL PERMIT NO. _____

So. Fla Water Mgmt P.O. Box 1 West Palm Bch FL 33402
Owner Tony Lubrano Address 2928 City 50 State 135 Zip H-310P
Contractor's Name Tony Lubrano License No. 40052 Completion Date _____ Casing Depth _____ Total Depth _____ Well # _____
Driller's Name _____ Registration No. _____


TYPE OF WORK: Construct (✓) Repair () Abandon ()
WELL USE: Domestic Well () Public () Monitor () Test (✓)
 Irrigation () Fire Well () Other _____
METHOD: Rotary with MUD (✓) or Air (), Cable Tool (), Jet ()
 Casing Driven (), Other _____
STATIC WATER LEVEL _____ Ft. below top of casing
PUMPING WATER LEVEL _____ Ft. after _____ Hrs. at _____ GPM
PUMP SIZE _____ H.P. CAPACITY _____ GPM
PUMP TYPE _____ INTAKE DEPTH _____
 From top of ground

LOCATION
Located Near Big Cypress Indian Reserv.
County Hardy
SE NW 3 48 33
¼ ¼ Section Township Range

Latitude-Longitude _____

Cuttings sent to District? (✓) Yes
 () No

Note: PWS Wells attach a site map if well location is different from site location on permit application.



LOCATE IN SECTION

Grout	Casing & Screen	Depth (ft)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes Give color, grain size, and type of material Note cavities, depth to producing zones.
		From	To	
	2" 6"	0	5	Sand
	7 7	7	18	clay
		18	20	shell
		20	35	shell clay
	45' 55' 6"	35	100	grey limestone shell
		7	100 135	tan sandstone
			135	
Number of bags				
8				

Casing: Black Steel () Galv. () PVC (✓) Fiberglass ()
Screen: Type PVC Slot size .050
Screened from 55 (ft.) to 135 (ft.)
Type of grout with % additives Neat
Water: Clear (✓) Colored () Sulphur () Salty () Iron ()
Conductivity _____ Chlorides _____ mg/l

WELL COMPLETION REPORT


FORM 0124
Rev. 4/85

WELL PERMIT NO. _____

So. Fla. Water Mgmt PO Box V West Palm Beach FL 33402
 Owner Address City State Zip
 Tony Lubrano 2928 8/5/86 50' 135 H-310
 Contractor's Name License No. Completion Date Casing Depth Total Depth Well #
 Tony Lubrano 40052 3 wells Tam-1
 Driller's Name Registration No. Tam-2

TYPE OF WORK: Construct Repair () Abandon ()
 WELL USE: Domestic Well () Public () Monitor Test
 Irrigation () Fire Well () Other _____
 METHOD: Rotary with MUD or Air (), Cable Tool (), Jet ()
 Casing Driven () Other _____
 STATIC WATER LEVEL 2 Ft. below top of casing
 PUMPING WATER LEVEL _____ Ft. after _____ Hrs. at _____ GPM
 PUMP SIZE _____ H.P. CAPACITY _____ GPM
 PUMP TYPE _____ INTAKE DEPTH _____
 From top of ground

LOCATION
 Located Near Big Cypress
 Indian Reserv.
 County Hendry
 SE NW 3 48 33
 1/4 1/4 Section Township Range



Cuttings sent to District? Yes
 () No

Note: PWS Wells attach a site map if well location is different from site location on permit application.

Grout	Casing & Screen	Depth (ft)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Give color, grain size, and type of material. Note cavities, depth to producing zones.
		From	To	
2"	2"	0	7	Sand
?	?	7	18	Clay
45'	?	18	20	Shell
		20	25	shell, clay
	55'	25	35	shell white clay
	2"	35	100	grey limestone shell
	?	100	135	tan sandstone
		135	170	dk green clay
		135	170	white clay limestone
		450	482	white limestone
Number of bags				Note: well plugged back up to 135
6				

Casing: Black Steel () Galv. () PVC Fiberglass ()
 Screen: Type PVC Slot size .020
 Screened from 55' (ft.) to 135 (ft.)
 Type of grout with % additives Neat no additives
 Water: Clear Colored () Sulphur () Salty () Iron ()
 Conductivity _____ Chlorides _____ mg/l

