

**WELL COMPLETION REPORT**

FORM 0124  
Rev. 4/85

**WELL PERMIT NO.** \_\_\_\_\_

Owner USGS Address 6552 SE Federal Hwy City Stuart State FL Zip 34997  
 License No. 2928 Completion Date 11/8/88 Casing Depth 95' Total Depth 105' Well # M-1254  
 Contractor's Signature Tony Lubrano Registration No. \_\_\_\_\_  
 Driller's Name \_\_\_\_\_

TYPE OF WORK: Construct ( ) Repair (  ) Abandon ( )  
 WELL USE: Domestic Well ( ) Public ( ) Monitor (  ) Test ( )  
 Irrigation ( ) Fire Well ( ) Other \_\_\_\_\_  
 METHOD: Rotary with MUD (  ) or Air ( ) , Cable Tool ( ) , Jet ( )  
 Casing Driven ( ) , Other \_\_\_\_\_  
 STATIC WATER LEVEL \_\_\_\_\_ Ft. below top of casing  
 PUMPING WATER LEVEL \_\_\_\_\_ Ft. after \_\_\_\_\_ Hrs. at \_\_\_\_\_ GPM  
 PUMP SIZE \_\_\_\_\_ H.P. CAPACITY \_\_\_\_\_ GPM  
 PUMP TYPE \_\_\_\_\_ INTAKE DEPTH \_\_\_\_\_  
 From top of ground

LOCATION  
 Located Near Savannah  
Rd & Commercial Jensen  
 County Martin  
 NW NW 22 37S 41E  
 1/4 1/4 Section Township Range  
271444 801411  
 Latitude-Longitude

|  |  |  |  |
|--|--|--|--|
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |

Cuttings sent to District? (  ) Yes  
 ( ) No

LOCATE IN SECTION

**Note: PWS Wells attach a site map if well location is different from site location on permit application.**

| Grout          | Casing & Screen | Depth (ft) |     | DRILL CUTTINGS LOG<br>Examine cuttings every 20 ft. or at formation changes<br>Give color, grain size, and type of material<br>Note cavities, depth to producing zones. |
|----------------|-----------------|------------|-----|---|
|                |                 | From       | To  |   |
| 2"             | 2"              | 0          | 8   | sand  |
|                |                 | 8          | 10  | hardpan   |
|                |                 | 10         | 45  | sand, orange to tan   |
|                |                 | 45         | 65  | shell, sand, silt   |
|                |                 | 65         | 83  | dk clay, carbonate, shell   |
| 85'            |                 | 83         | 93  | dk clay, shell, carbonate, silt   |
|                |                 | 93         | 125 | gray sandstone, shell   |
|                | 95' 2"          | 125        | 135 | shell, sandstone, silt, phosphate   |
|                |                 | 135        | 158 | phosph. silt, shell   |
|                |                 | 158        | 168 | sandstone, sand, shell  |
|                | 2" 105'         | 168        | 182 | green clay, limestone stringers   |
| Number of bags | 2 (plug)        |            |     |   |
| 2              | 182'            |            |     |   |

Casing: Black Steel ( ) Galv. ( ) PVC (  ) Fiberglass ( )

Screen: Type AC Slot size .02

Screened from 95 (ft.) to 105 (ft.)

Type of grout with % additives Neat

Water: Clear ( ) Colored ( ) Sulphur ( ) Salty ( ) Iron ( )

Conductivity \_\_\_\_\_ Chlorides \_\_\_\_\_ mg/l